

(DO NOT COVER UNTIL DISTRICT INSPECTS)

COIL BOX/METER SPECIFICATIONS:

SINGLE 3/4" METER INSTALLATION:


METER - 5/8" x 3/4" Badger Recordall Nutating Disc Flowmeter, LL Bronze External Thread Body, Noryl Chamber, Plastic Thrust Roller, Bronze Bottom, Meter Mounted Low Temp Register, No Connections, NSF G1, Cubic Feet Reader
 COIL BOX - Mueller No. 250 CS 15 36 LSBSN
 LID - Mueller No. 790007
 INSULATION RING - Mueller No. 790022

DOUBLE 3/4" METER INSTALLATION:

(2) METERS - see single 3/4" meter installation above
 COIL BOX - Mueller No. 250 CD 18 36 LSBSN
 LID - Mueller No. 790018
 INSULATION RING - Mueller No. 790153

SINGLE 1" METER INSTALLATION:

METER - 1" Badger Recordall Nutating Disc Flowmeter, LL Bronze External Thread Body, Noryl Chamber, Plastic Thrust Roller, Bronze Bottom, Meter Mounted Low Temp Register, No Connections, NSF G1, Cubic Feet Reader
 COIL BOX - Mueller No. 330 CS 18 36 LSBSN
 LID - Mueller No. 790018
 INSULATION RING - Mueller No. 790153



CUSTOMER INITIAL: _____

NOTES:
 ALL DOMESTIC DEVICES AND FITTINGS MUST BE LEAD FREE.

MATERIAL SUBSTITUTIONS OR DETERMINATION OF EQUAL ARE AT THE SOLE DISCRETION OF LAKE CHELAN RECLAMATION DISTRICT.

SERVICE LINE TO BE 90° OFF MAIN LINE.

MAGNETIC TAPE TO BE BURIED OVER SERVICE LINE FOR LOCATION.

TITLE DOMESTIC WATER SERVICE w/ DCVA - CONTRACTOR VS STANDARD DOMESTIC DETAIL	
SHEET 20B OF SET	DWG SCALE NO SCALE

