

Eurofins Microbiology Laboratories (Cascade)

 1008 W Ahtanum Rd Suite 2
 Union Gap, Washington 98803
 1-509-452-7707
 Micro-cascade@eurofinsus.com

Lake Chelan Reclam. Dist.

Client Code: BX0000113

 Dave Walters
 80 Wapato Way
 Manson, WA 98831

ANALYTICAL REPORT

AR-23-BX-001553-01

Received On: 07Jun2023
Reported On: 08Jun2023

Eurofins Sample Code: 101-2023-06070062	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: LC-3-8	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	6.2 MPN/100 ml

Eurofins Sample Code: 101-2023-06070063	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: A-8-2	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	6.3 MPN/100 ml

Eurofins Sample Code: 101-2023-06070064	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: A-3-17	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2023-06070065	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: B-4-12	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
------------------	---------------

Dave Walters
 80 Wapato Way
 Manson, WA 98831

ANALYTICAL REPORT

AR-23-BX-001553-01

Received On: 07Jun2023
 Reported On: 08Jun2023

Eurofins Sample Code: 101-2023-06070065	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: B-4-12	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	3.1 MPN/100 ml

Eurofins Sample Code: 101-2023-06070066	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: C-2-8	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	3 MPN/100 ml

Eurofins Sample Code: 101-2023-06070067	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: D-3-6	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2023-06070068	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: E-2-3	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	2 MPN/100 ml

Eurofins Sample Code: 101-2023-06070069	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: F-4	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	7.5 MPN/100 ml

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-23-BX-001553-01

Received On: 07Jun2023
Reported On: 08Jun2023

Eurofins Sample Code: 101-2023-06070070	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: G-1-1	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	6.3 MPN/100 ml

Eurofins Sample Code: 101-2023-06070071	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: H-3	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2023-06070072	Sample Registration Date: 07Jun2023
Client Sample Code:	Condition Upon Receipt: acceptable, 12°C
Sample Description: LL-PP	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Jun2023
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	51 MPN/100 ml

Respectfully Submitted,



Kyle Johnson
Business Unit Manager Cascade Analytical (US)

Lake Chelan Reclam. Dist.

Client Code: BX0000113

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-23-BX-001553-01

Received On: 07Jun2023
Reported On: 08Jun2023

Results shown in this report relate solely to the item submitted for analysis. | Any opinions/interpretations expressed on this report are given independent of the laboratory's scope of accreditation. | All results are reported on an "As Received" basis unless otherwise stated. | Reports shall not be reproduced except in full without written permission of Eurofins Scientific, Inc. | All work done in accordance with Eurofins General Terms and Conditions of Sale: www.eurofinsus.com/terms_and_conditions.pdf | √ Indicates a subcontract test to a different lab. Lab(s) are listed at end of the report. For further details about the performing labs please contact your customer service contact at Eurofins. Measurement of uncertainty can be obtained upon request.