

Eurofins Microbiology Laboratories (Wenatchee)

3019 GS Center Road
 Wenatchee, WA 98801
 1-800-545-4206
 Cascade_Client_Services@eurofinsus.com

Lake Chelan Reclam. Dist.

Client Code: BX0000113

Dave Walters
 P O Box J
 Manson, WA 98831

ANALYTICAL REPORT

AR-21-BX-001870-01

Received On: 15Sep2021
Reported On: 16Sep2021

Eurofins Sample Code: 101-2021-09150017		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: LC-3-8		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2021-09150018		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: A-8-2		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2021-09150019		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: A-3-17		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2021-09150020		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: B-4-12		Sample Reference:	

Dave Walters
P O Box J
Manson, WA 98831

ANALYTICAL REPORT

AR-21-BX-001870-01

Received On: 15Sep2021
Reported On: 16Sep2021

Eurofins Sample Code: 101-2021-09150020**Sample Registration Date:** 15Sep2021**Client Sample Code:****Condition Upon Receipt:**acceptable, 16°C**Sample Description:** B-4-12**Sample Reference:****ZM5U6 - E. coli - SMEWW 9223 B****Reference**
SMEWW 9223 B**Accreditation**
ISO/IEC 17025:2017
PJLA 74266**Completed**
16Sep2021**Parameter**
Escherichia coli**Result**
4.1 MPN/100 ml**Eurofins Sample Code:** 101-2021-09150021**Sample Registration Date:** 15Sep2021**Client Sample Code:****Condition Upon Receipt:**acceptable, 16°C**Sample Description:** C-2-8**Sample Reference:****ZM5U6 - E. coli - SMEWW 9223 B****Reference**
SMEWW 9223 B**Accreditation**
ISO/IEC 17025:2017
PJLA 74266**Completed**
16Sep2021**Parameter**
Escherichia coli**Result**
< 1 MPN/100 ml**Eurofins Sample Code:** 101-2021-09150022**Sample Registration Date:** 15Sep2021**Client Sample Code:****Condition Upon Receipt:**acceptable, 16°C**Sample Description:** D-3-6**Sample Reference:****ZM5U6 - E. coli - SMEWW 9223 B****Reference**
SMEWW 9223 B**Accreditation**
ISO/IEC 17025:2017
PJLA 74266**Completed**
16Sep2021**Parameter**
Escherichia coli**Result**
2 MPN/100 ml**Eurofins Sample Code:** 101-2021-09150023**Sample Registration Date:** 15Sep2021**Client Sample Code:****Condition Upon Receipt:**acceptable, 16°C**Sample Description:** E-2-3**Sample Reference:****ZM5U6 - E. coli - SMEWW 9223 B****Reference**
SMEWW 9223 B**Accreditation**
ISO/IEC 17025:2017
PJLA 74266**Completed**
16Sep2021**Parameter**
Escherichia coli**Result**
1 MPN/100 ml**Eurofins Sample Code:** 101-2021-09150024**Sample Registration Date:** 15Sep2021**Client Sample Code:****Condition Upon Receipt:**acceptable, 16°C**Sample Description:** F-4**Sample Reference:**

Dave Walters
P O Box J
Manson, WA 98831

ANALYTICAL REPORT

AR-21-BX-001870-01

Received On: 15Sep2021
Reported On: 16Sep2021

Eurofins Sample Code: 101-2021-09150024		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: F-4		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	2 MPN/100 ml

Eurofins Sample Code: 101-2021-09150025		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: G-1-1		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	3.1 MPN/100 ml

Eurofins Sample Code: 101-2021-09150026		Sample Registration Date: 15Sep2021	
Client Sample Code:		Condition Upon Receipt: acceptable, 16°C	
Sample Description: H-3		Sample Reference:	
ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 16Sep2021

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Respectfully Submitted,



Brianna Buschbach
60 MGRSCIEN

Lake Chelan Reclam. Dist.

Client Code: BX0000113

Dave Walters
P O Box J
Manson, WA 98831

ANALYTICAL REPORT

AR-21-BX-001870-01

Received On: 15Sep2021
Reported On: 16Sep2021

Results shown in this report relate solely to the item submitted for analysis. | Any opinions/interpretations expressed on this report are given independent of the laboratory's scope of accreditation. | All results are reported on an "As Received" basis unless otherwise stated. | Reports shall not be reproduced except in full without written permission of Eurofins Scientific, Inc. | All work done in accordance with Eurofins General Terms and Conditions of Sale: www.eurofinsus.com/terms_and_conditions.pdf | √ Indicates a subcontract test to a different lab. Lab(s) are listed at end of the report. For further details about the performing labs please contact your customer service contact at Eurofins. Measurement of uncertainty can be obtained upon request.