

Eurofins Microbiology Laboratories (Cascade)

3019 GS Center Road
 Wenatchee, Washington 98801
 1-800-545-4206
 Cascade_Client_Services@eurofinsus.com

Lake Chelan Reclam. Dist.

Client Code: BX0000113

Dave Walters
 80 Wapato Way
 Manson, WA 98831

ANALYTICAL REPORT

AR-22-BX-002936-01

Received On: 07Sep2022
Reported On: 08Sep2022

Eurofins Sample Code: 101-2022-09070011
Client Sample Code:
Sample Description: LC-3-8

Sample Registration Date: 07Sep2022
Condition Upon Receipt: acceptable, 14°C
Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B

Reference
 SMEWW 9223 B

Accreditation
 ISO/IEC 17025:2017
 PJLA 74266

Completed
 08Sep2022

Parameter
 Escherichia coli

Result
 < 1 MPN/100 ml

Eurofins Sample Code: 101-2022-09070012
Client Sample Code:
Sample Description: A-8-2

Sample Registration Date: 07Sep2022
Condition Upon Receipt: acceptable, 14°C
Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B

Reference
 SMEWW 9223 B

Accreditation
 ISO/IEC 17025:2017
 PJLA 74266

Completed
 08Sep2022

Parameter
 Escherichia coli

Result
 1 MPN/100 ml

Eurofins Sample Code: 101-2022-09070013
Client Sample Code:
Sample Description: A-3-17

Sample Registration Date: 07Sep2022
Condition Upon Receipt: acceptable, 14°C
Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B

Reference
 SMEWW 9223 B

Accreditation
 ISO/IEC 17025:2017
 PJLA 74266

Completed
 08Sep2022

Parameter
 Escherichia coli

Result
 1 MPN/100 ml

Eurofins Sample Code: 101-2022-09070014
Client Sample Code:
Sample Description: B-4-12

Sample Registration Date: 07Sep2022
Condition Upon Receipt: acceptable, 14°C
Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B

Reference
 SMEWW 9223 B

Accreditation
 ISO/IEC 17025:2017
 PJLA 74266

Completed
 08Sep2022

Parameter
 Escherichia coli

Result
 3.1 MPN/100 ml

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-22-BX-002936-01

Received On: 07Sep2022
Reported On: 08Sep2022

Eurofins Sample Code: 101-2022-09070015	Sample Registration Date: 07Sep2022
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: C-2-8	Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Sep2022
---------------------------------------	----------------------------------	--	-------------------------------

Parameter Escherichia coli	Result 2 MPN/100 ml
--------------------------------------	-------------------------------

Eurofins Sample Code: 101-2022-09070016	Sample Registration Date: 07Sep2022
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: D-3-6	Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Sep2022
---------------------------------------	----------------------------------	--	-------------------------------

Parameter Escherichia coli	Result < 1 MPN/100 ml
--------------------------------------	---------------------------------

Eurofins Sample Code: 101-2022-09070017	Sample Registration Date: 07Sep2022
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: E-2-3	Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Sep2022
---------------------------------------	----------------------------------	--	-------------------------------

Parameter Escherichia coli	Result < 1 MPN/100 ml
--------------------------------------	---------------------------------

Eurofins Sample Code: 101-2022-09070018	Sample Registration Date: 07Sep2022
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: F-4	Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Sep2022
---------------------------------------	----------------------------------	--	-------------------------------

Parameter Escherichia coli	Result < 1 MPN/100 ml
--------------------------------------	---------------------------------

Eurofins Sample Code: 101-2022-09070019	Sample Registration Date: 07Sep2022
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: G-1-1	Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 08Sep2022
---------------------------------------	----------------------------------	--	-------------------------------

Parameter Escherichia coli	Result 1 MPN/100 ml
--------------------------------------	-------------------------------

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-22-BX-002936-01

Received On: 07Sep2022
Reported On: 08Sep2022

Eurofins Sample Code: 101-2022-09070020
Client Sample Code:
Sample Description: H-3

Sample Registration Date: 07Sep2022
Condition Upon Receipt: acceptable, 14°C
Sample Reference:

ZM5U6 - E. coli - SMEWW 9223 B

Reference
SMEWW 9223 B

Accreditation
ISO/IEC 17025:2017
PJLA 74266

Completed
08Sep2022

Parameter
Escherichia coli

Result
< 1 MPN/100 ml

Respectfully Submitted,



Kyle Johnson
Business Unit Manager

Results shown in this report relate solely to the item submitted for analysis. | Any opinions/interpretations expressed on this report are given independent of the laboratory's scope of accreditation. | All results are reported on an "As Received" basis unless otherwise stated. | Reports shall not be reproduced except in full without written permission of Eurofins Scientific, Inc. | All work done in accordance with Eurofins General Terms and Conditions of Sale: www.eurofinsus.com/terms_and_conditions.pdf | ✓ Indicates a subcontract test to a different lab. Lab(s) are listed at end of the report. For further details about the performing labs please contact your customer service contact at Eurofins. Measurement of uncertainty can be obtained upon request.