

Eurofins Microbiology Laboratories (Cascade)

 1008 W. Ahtanum Rd
 Union Gap, Washington 98903
 1-509-452-7707
 Micro-cascade@eurofinsus.com

Lake Chelan Reclam. Dist.

 Dave Walters
 80 Wapato Way
 Manson, WA 98831

ANALYTICAL REPORT

AR-24-BX-006080-01

Client Code: BX0000113
PO#: # Irrigation Samples

Received On: 03Jun2024
Reported On: 04Jun2024

Eurofins Sample Code: 101-2024-06030114	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: Lake Chelan Sample	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	52.9 MPN/100 ml

Eurofins Sample Code: 101-2024-06030115	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: LC-3-8	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	3.1 MPN/100 ml

Eurofins Sample Code: 101-2024-06030116	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: A-8-2	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	4.1 MPN/100 ml

Eurofins Sample Code: 101-2024-06030117	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: A-3-17	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	6.2 MPN/100 ml

ANALYTICAL REPORT

AR-24-BX-006080-01

Client Code: BX0000113
PO#: # Irrigation Samples

Received On: 03Jun2024
Reported On: 04Jun2024

Eurofins Sample Code: 101-2024-06030117	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: A-3-17	Sample Reference:

Eurofins Sample Code: 101-2024-06030118	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: B-4-12	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	10.9 MPN/100 ml

Eurofins Sample Code: 101-2024-06030119	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: C-2-8	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	16 MPN/100 ml

Eurofins Sample Code: 101-2024-06030120	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: D-3-6	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2024-06030121	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: E-2-3	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	9.7 MPN/100 ml

Eurofins Sample Code: 101-2024-06030122	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: F-4	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Lake Chelan Reclam. Dist.

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-24-BX-006080-01

Client Code: BX0000113
PO#: # Irrigation Samples

Received On: 03Jun2024
Reported On: 04Jun2024

Eurofins Sample Code: 101-2024-06030122	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: F-4	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	2 MPN/100 ml

Eurofins Sample Code: 101-2024-06030123	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: G-1-1	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------


Parameter	Result
E. coli	13.4 MPN/100 ml

Eurofins Sample Code: 101-2024-06030124	Sample Registration Date: 03Jun2024
Client Sample Code:	Condition Upon Receipt: acceptable, 16.6°C
Sample Description: H-3	Sample Reference:

ZM7AU - E. coli - SM 9223.B	Reference SM 9223.B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 04Jun2024
------------------------------------	-------------------------------	--	-------------------------------

Parameter	Result
E. coli	3 MPN/100 ml

Respectfully Submitted,



Chandrashekhar Aradhya
Team Lead - US Reporting

Lake Chelan Reclam. Dist.

Dave Walters
80 Wapato Way
Manson, WA 98831

ANALYTICAL REPORT

AR-24-BX-006080-01

Client Code: BX0000113

PO#: # Irrigation Samples

Received On: 03Jun2024

Reported On: 04Jun2024

Results shown in this report relate solely to the item submitted for analysis. | Any opinions/interpretations expressed on this report are given independent of the laboratory's scope of accreditation. | All results are reported on an "As Received" basis unless otherwise stated. | Reports shall not be reproduced except in full without written permission of Eurofins Scientific, Inc. | All work done in accordance with Eurofins General Terms and Conditions of Sale: www.eurofinsus.com/terms_and_conditions.pdf | ✓ Indicates a subcontract test to a different lab. Lab(s) are listed at end of the report. For further details about the performing labs please contact your customer service contact at Eurofins. Measurement of uncertainty can be obtained upon request.