

Eurofins Microbiology Laboratories (Wenatchee)

 3019 GS Center Road
 Wenatchee, WA 98801
 1-800-545-4206
 Cascade_Client_Services@eurofinsus.com

Lake Chelan Reclam. Dist.

Client Code: BX0000113

 Dave Walters
 P O Box J
 Manson, WA 98831

ANALYTICAL REPORT

Received On: 01Sep2020
Reported On: 03Sep2020

AR-20-BX-001753-01

Eurofins Sample Code: 101-2020-09010058		Sample Registration Date: 01Sep2020	
Client Sample Code:		Condition Upon Receipt: acceptable, 14°C	
Sample Description: LC-3-8-		Sample Reference:	
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010059		Sample Registration Date: 01Sep2020	
Client Sample Code:		Condition Upon Receipt: acceptable, 14°C	
Sample Description: A-8-2-		Sample Reference:	
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	3 MPN/100 ml

Eurofins Sample Code: 101-2020-09010060		Sample Registration Date: 01Sep2020	
Client Sample Code:		Condition Upon Receipt: acceptable, 14°C	
Sample Description: A-3-17-		Sample Reference:	
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010061		Sample Registration Date: 01Sep2020	
Client Sample Code:		Condition Upon Receipt: acceptable, 14°C	
Sample Description: B-4-12-		Sample Reference:	
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	2 MPN/100 ml

Dave Walters
 P O Box J
 Manson, WA 98831

ANALYTICAL REPORT

AR-20-BX-001753-01

Received On: 01Sep2020
 Reported On: 03Sep2020

Eurofins Sample Code: 101-2020-09010061	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: B-4-12-	Sample Reference:

Eurofins Sample Code: 101-2020-09010062	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: C-2-8-	Sample Reference:

ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020
--	----------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010063	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: D-3-6-	Sample Reference:

ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020
--	----------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010064	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: E-2-3-	Sample Reference:

ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020
--	----------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	< 1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010065	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: F-4-	Sample Reference:

ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020
--	----------------------------------	--	-------------------------------

Parameter	Result
Escherichia coli	1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010066	Sample Registration Date: 01Sep2020
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C
Sample Description: G-1-1-	Sample Reference:

ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020
--	----------------------------------	--	-------------------------------

Dave Walters
P O Box J
Manson, WA 98831

ANALYTICAL REPORT

AR-20-BX-001753-01

Received On: 01Sep2020
Reported On: 03Sep2020


Eurofins Sample Code: 101-2020-09010066	Sample Registration Date: 01Sep2020		
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C		
Sample Description: G-1-1-	Sample Reference:		
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	<1 MPN/100 ml

Eurofins Sample Code: 101-2020-09010067	Sample Registration Date: 01Sep2020		
Client Sample Code:	Condition Upon Receipt: acceptable, 14°C		
Sample Description: H-3-	Sample Reference:		
ZM5U6 - E. coli MPN/100mL SM 9223 B Quanti-Tray	Reference SMEWW 9223 B	Accreditation ISO/IEC 17025:2017 PJLA 74266	Completed 02Sep2020

Parameter	Result
Escherichia coli	4 MPN/100 ml

Respectfully Submitted,



Desiree Alling
30 SCIENTIST

Results shown in this report relate solely to the item submitted for analysis. | Any opinions/interpretations expressed on this report are given independent of the laboratory's scope of accreditation. | All results are reported on an "As Received" basis unless otherwise stated. | Reports shall not be reproduced except in full without written permission of Eurofins Scientific, Inc. | All work done in accordance with Eurofins General Terms and Conditions of Sale: www.eurofinsus.com/terms_and_conditions.pdf | √ Indicates a subcontract test to a different lab. Lab(s) are listed at end of the report. For further details about the performing labs please contact your customer service contact at Eurofins. Measurement of uncertainty can be obtained upon request.